

MICROBIOLOGICAL ANALYSIS

Nov-23

	LOCATION	SOURCE	RESULTS
1	Aklatang Emilio Aguinaldo(AEA)	DF	Passed
4	HighSchool 1st Bldg -GF	DF	Passed
6	Basic Education Department, 2nd Bldg -3rd flr.	DF	Passed
7	HighSchool 2nd Bldg Connecting	DF	Passed
8	Julian Felipe Hall (JFH)	DF	Passed
9	Ladislao Diwa Hall (LDH)	DF	Passed
11	Pump 1	Faucet	Passed
15	University Health Clinic - West (UHC)	Water Purifier	Passed
16	Swimming Pool	DF	Passed
17	College of Business Administration and Accountancy Groud Floor (CBAA)	DF	Passed

REFERENCES:

Passed - DOH PNSDW - Philippine National standards for Drinking water 2017

Standard Methods for the Examination of Water and Wastewater 23rd Edition

Standard values for drinking water (DOH PNSDW 2017)

LEGEND:

REGULATORY LIMIT

Total Coliform - < 1.1

Thermotolerant Coliform - < 1.1

Heterotrophic Plate Count - < 500